

Addendum 1 Feb. 14, 2018 - ABHS Request for Solutions - Interior Cabling

Clarifications

1. All installation work must be supervised by a person certified by a recognized industry organization to install category 6a cables and terminations. Please include details in the proposal.
2. The connections between the MDF and IDF's may be fiber or copper. The connections need to be terminated in a patch panel in each rack. However preference will be given to fiber.
3. The proposal must include all cabling hardware for the three new IDF's and connections between them and the MDF. No switching equipment is required.