

Addendum 2 Feb. 20, 2018 - ABHS

Request for Solutions - Interior Cabling

Questions

1. Do we need to run Plenum cable in Indaba?

Yes

2. Can we quote the project using category 6 cabling?

You must include category 6a in the quote. If you feel another solution is appropriate you may include that. Please note in the proposal why you feel your choice is better.

3. The room indicated on your maps for the IDF's is too small. May we locate the IDF's elsewhere?

Because the locations we indicated are too small, you may ignore them. We have decided to modify the needs to indicate one IDF is needed for both the second and third floor. Those IDF's will be combined and located in the skylight room. We still need an IDF located in the basement